

# Annual Drinking Water Quality Report

## Borough of Sea Girt

### For the Year 2014, Results from the Year 2013

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. We have three wells and we purchase water from the New Jersey Water Supply Authority, Manasquan Reservoir Water Supply System. Our wells draw their water from the lower Kirkwood/Cohansey Aquifer and Englishstown Aquifers. The Manasquan Water Treatment Plant, located on Hospital Road in the Allenwood section of Wall Township, is owned by the Monmouth County Improvement Authority and is operated by the New Jersey Water Supply Authority. The Manasquan Water Treatment Plant takes its water from the Manasquan River in Wall Township and the Manasquan Reservoir in Howell Township.

The New Jersey Department of Environmental Protection (NJDEP) has completed and issued Source Water Assessment Reports and Summaries for these public water systems, which are available at [WWW.state.nj.us/dep/swap](http://WWW.state.nj.us/dep/swap) or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system to obtain information regarding Sea Girt's Source Water Assessment. The source water susceptibility ratings and a list of potential contaminant sources for these water systems is included.

**We are pleased to report that our drinking water meets all federal and state safety requirements.**

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

<b>Borough of Sea Girt Test Results</b>						
PWS ID # NJ1344001						
Contaminant	Violation Y/N	Level Detected	Units of Measure ment	MC LG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants:</b>						
Combined Radium 228 & 226 Test results Yr. 2012	N	2.1	pCi/l	0	5	Erosion of natural deposits
<b>Inorganic Contaminants:</b>						
Copper Test results Yr. 2011 Result at 90 <sup>th</sup> Percentile	N	< 0.03 No samples exceeded the action level.	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Test results Yr. 2011 Result at 90 <sup>th</sup> Percentile	N	< 1 No samples exceeded the action level.	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection Byproducts:</b>						
<b>Disinfection Byproducts Stage-1</b>						
TTHM Total Trihalomethanes Test results Yr. 2013	N	Range = 5 - 39 Annual Average = 22	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids Test results Yr. 2013	N	Range = ND - 34 Annual Average = 14	ppb	N/A	60	By-product of drinking water disinfection
<b>Disinfection Byproducts Stage-2</b>						
TTHM Total Trihalomethanes Test results Yr. 2013	N	23	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids Test results Yr. 2013	N	69	ppb	N/A	60	By-product of drinking water disinfection
<b>Regulated Disinfectants</b>		<b>Level Detected</b>		<b>MRDL</b>		<b>MRDLG</b>
Chlorine Test results Yr. 2013		Average = 0.8 ppm		4.0 ppm		4.0 ppm

A new Disinfection Byproduct Rule called Stage II took effect for this system in 2013. The first compliance calculations for this system will be available after the third quarter of 2014 once a full year of monitoring has been completed. After the third quarter of 2013, Stage I was phased out. Stage II HAA5 and TTHM compliance is based on the locational running annual average (LRAA) calculated at each monitoring location. The LRAA for Stage II HAA5s and TTHMs is not included in this report since Stage II monitoring began in the fourth quarter of 2013, so there was only results for one quarter of 2013 and the LRAA calculation is based on four completed quarters of results.

The Sea Girt Water Department and the NJWSA Manasquan Water Supply System routinely monitor for contaminants in your drinking water according to Federal and State laws. This tables show the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2013. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

**If you have any questions about this report or concerning your water utility, please call the Sea Girt Water Department at 732-449-0911. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Borough Council meetings at the Sea Girt Elementary School. Meetings are held on the second and fourth Wednesdays of each month at 7:30 p.m.**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

**Lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Sea Girt Water Department and the Manasquan Water Supply System are responsible for providing high quality drinking water, but can not control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 second to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at <http://www.epa.gov/safewater/lead>.

### **DEFINITIONS**

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm)** or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb)** or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.

**Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Total Organic Carbon** – Total Organ Carbon (TOC) has no health effects. However, TOC provides a medium for the formation of disinfection byproducts. The *Treatment Technique* for TOC requires that 35% - 45% of the TOC in the raw water is removed through a treatment processes.

**Turbidity** – Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium microbial growth. Turbidity is measured as an indication of the effectiveness of the filtration process. The *Treatment Technique* for turbidity requires that no individual sample exceeds 1 NTU and 95% of the samples collected during the month must be less than 0.3 NTU.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. Our system received monitoring waivers for all of these types of contaminants. The Manasquan Water Supply System received a monitoring waiver for synthetic organic contaminants.

**We at Sea Girt Water Department work hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.**

<b>Manasquan Water Supply 2013 Test Results</b>						
<b>PWSID # NJ1352005</b>						
<b>Contaminant</b>	<b>Violation Y/N</b>	<b>Level Detected</b>	<b>Units of Measurement</b>	<b>MC LG</b>	<b>MCL</b>	<b>Likely Source of Contamination</b>
<b>Microbiological Contaminants:</b>						
Turbidity	N	Range = 0.01 – 0.17 99.95% < 0.3 NTU	NTU	N/A	TT 95% of monthly samples < 0.3 NTU	Soil runoff
Total Organ Carbon (TOC)	N	Range = 26.3 – 67.9 Avg. Removal = 42%	%	N/A	TT 35% - 50% removal	Soil runoff
<b>Radioactive Contaminants:</b>						
Gross Alpha Test results Yr. 2011	N	Range = 0.5 – 1.25 Average = 0.96	pCi/l	0	15	Erosion of natural deposits
Radium- 228 Test results Yr. 2011	N	Range = ND – 0.18 Average = < 1	pCi/l	N/A	N/A	Erosion of natural deposits
<b>Inorganic Contaminants:</b>						
Barium	N	0.032	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride	N	0.16	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen)	N	0.14	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Disinfection Byproducts:</b>						
TTHM Total Trihalomethanes	N	Range = 6 - 26 Highest Average = 26 (LRAA)	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids	N	Range = 10 - 19 Highest Average = 19 (LRAA)	ppb	N/A	60	By-product of drinking water disinfection
<b>Regulated Disinfectants</b>		<b>Level Detected</b>		<b>MRDL</b>		<b>MRDLG</b>
Chlorine		Range = 0.73 – 2.0 ppm Average = 1.3 ppm		4.0 ppm		4.0 ppm

HAA5 and TTHM compliance is based on a Locational Running Annual Average (LRAA), calculated at each monitoring location. The LRAA calculation is based on four completed quarters of monitoring results.

**Cryptosporidium**

Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Cryptosporidium is usually removed through the filtration process and inactivated by other treatment processes such as ozonation. In order to check for the presence of Cryptosporidium, the USEPA issued the Long Term Enhanced Surface Water Treatment Rule in January 2006. As part of this rule, the Manasquan System began monthly sampling and testing for Cryptosporidium in April 2008 and this testing continued through its completion in March 2010. The sample results did not show any presence of Cryptosporidium.

## Sea Girt Water Department-PWSID # NJ1344001

Sea Girt Water Department is a public community water system consisting of 3 wells and 1 purchased surface water source.

This system's source water comes from the following aquifers: Englishtown Aquifer System, Atlantic City "800-foot" Sand Aquifer

This system purchases water from the following water system: Manasquan Water Supply

### Susceptibility Ratings for Sea Girt Water Department Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes' susceptibility to radionuclides was not determined and they all received a low rating.

**If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water.** The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

Sources	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfection Byproduct Precursors		
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L
Wells - 3			3			3			3			3		1	2			3			3			3
GUDI - 0																								
Surface water intakes - 0																								

**Pathogens:** Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

**Nutrients:** Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

**Volatile Organic Compounds:** Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

**Pesticides:** Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

**Inorganics:** Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

**Radionuclides:** Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

**Radon:** Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

**Disinfection Byproduct Precursors:** A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.